

EV Battery Charger Display

PN 7517

The EV Battery Charger Display provides two options to monitor your battery banks. When connected to a P12 Battery Charger it can display the charger's Summary screen—displaying voltage, current, charging stage, and errors from the charger. When the charger is off or if no P12 charger is connected, the unit will display the voltage on up to 3 battery banks in an easy to read bar graph display.

Specifications

Display Size: 55mm x 28mm Display Type: Yellow OLED

Input Voltage: 6 to 36 Volts DC, reverse polarity protected

Amperage Draw:

Maximum: 50 mA

Minimum: < 1 mA in Standby Mode

Standby Mode The 7517 has the option of a power saving

Standby Mode which turns the display off after 4 hours of being stationary. The 7517 will resume normal function upon movement of the vehicle or by

tapping the unit several times in succession.

Accuracy: ± 1% at 36 Volts DC

Number of Inputs: 3 battery inputs with common reference.

Regulatory


Monitor face is IP66 – protected against powerful water jets when installed according to instructions.

Wiring and Installation

Please read and understand all instructions before beginning installation. Note: Pins 1 (Battery 1+) and G (DC Negative) are the power source for the unit and must be connected.

- 1) Disconnect all AC and DC sources.
- 2) Carefully prepare cut out hole for unit installation.
 - a. Check for pipes, wires, or other systems behind planned cutout area.
- 3) Set DIP Switches on back of unit for desired display setup. See page 2
- If connecting to multiple banks, ensure all banks have a Common Ground.
- 5) Run appropriately sized wires (see Wire Size / Length Chart) from the Positive of each bank and the Common Ground to the 4 position terminal block plug (included), leaving the fuses out of lines 1, 2, and 3 for now.
- 6) Place gasket around unit.
- Insert 4 position terminal block plug into unit. It is keyed and will only go one way.
- 8) If a P12 charger is installed, connect it to the EV Battery Charger Display using the Cat5e cable included.
- 9) Install unit into cutout.
 - a. Do not overtighten screws.
- 10) Insert fuses into lines 2 and 3 first. Then insert fuse into line 1. All fuses must be appropriately sized for the wiring used.

Included Components



Connector Pin Assignment


4 Pin Connector*	Function
1 Required Connection	Battery 1+
2	Battery 2+
3	Battery 3+
G Required Connection	DC Negative


^{*} The 4 Pin Connector supports wire sizes from 12-24 AWG

Wire Size / Length Chart

Length of Run - One way feet (meters)	Minimum Wire Gauge	Recommended Fuse Size (min-max)
0 - 10ft (0 - 3m)	22 AWG	1A - 2A
11 - 20ft (3 - 6m)	18 AWG	1A - 10A
21 - 40ft (6 - 12m)	16 AWG	1A - 15A
41 - 70ft (12 - 21m)	14 AWG	1A-20A
71 - 100ft (21 - 30m)	12 AWG	1A - 25A

^{**} All batteries must share a common ground





Bar Graph


Use if a P12 charger is not connected or the charger summary screen is not desired. When a P12 is connected, the display will show a lightning bolt when the charger is active. The bar graph will indicate when a channel is in Bulk or Absorption modes by a "Filling Up" graphic. When a channel moves to Pre-Float or Float mode the graphic will stop, this will occur independently for each channel.



With Standby Mode* (Default)



Without Standby Mode



P12 Summary Screen

When the connected P12 charger is ON, the unit will display the charger summary screen. When the connected P12 charger is off, the unit will display the bar graph display.




With Standby Mode*



Without Standby Mode

* Standby Mode: See specifications

Mounting Cutout



980023670 Rev. 001 page 2 of 2